



## Manufacturer's Declaration

### Coastal installation of Sunny Boy and Sunny Tripower inverters

All the Sunny Boy and Sunny Tripower inverters listed below have passed the salt spray tests in accordance with EN 60068-2-52. Consequently, they are suitable for coastal installation.

| SUNNY BOY      | SUNNY TRIPOWER   |
|----------------|------------------|
| SB1300TL-10    | STP 15000TL-10   |
| SB1600TL-10    | STP 17000TL-10   |
| SB 2100TL      | STP 15000TLEE-10 |
| SB 3000TL-21   | STP 20000TLEE-10 |
| SB 3600TL-21   | STP 5000TL-20    |
| SB 4000TL-21   | STP 6000TL-20    |
| SB 5000TL-21   | STP 7000TL-20    |
| SB 6000TL-21   | STP 8000TL-20    |
| SB 2500TLST-21 | STP 9000TL-20    |
| SB 3000TLST-21 | STP 10000TL-20   |
| SB 3600SE-10   | STP 12000TL-20   |
| SB 5000SE-10   | STP 20000TL-30   |
| SB 240-10      | STP 25000TL-30   |
| SB 2000HF-30   | STP 50-40        |
| SB 2500HF-30   | STP 50-JP-40     |
| SB 3000HF-30   | STP 50-US-40     |
|                | STP 33-US-41     |
|                | STP 50-US-41     |
|                | STP 62-US-41     |

Remark: The EN 60068-2-52 standard is not an integral part of the European directives for EU conformity and is therefore not specified in the EU Declaration of Conformity for the listed inverters.

Niestetal, 19.11.2018

**SMA Solar Technology AG**

A handwritten signature in black ink, appearing to read 'ppa. Johannes Kneip', is written over a light blue horizontal line.

ppa. Dr.-Ing. Johannes Kneip  
EVP Development Center & IT